

Operating Rooms

Comparative Results of the Microbiological Controls in Operating Rooms 2 and 4

Before After

OPERATING ROOM 2	Spot	November 2011 Ufc/m ³	November 2012 Ufc/m ³	March 2013 Ufc/m ³
	1	4	36	0
2	6	40	0	
3	6	46	0	
4	4	10	0	
5	2	8	2	
6	2	14	4	

OPERATING ROOM 4	Spot	November 2011 Ufc/m ³	November 2012 Ufc/m ³	March 2013 Ufc/m ³
	1	18	180	6
2	28	100	8	
3	16	110	6	
4	22	150	6	
5	6	94	2	
6	2	110	8	



Comparative Results of the Particle Controls in Operating Rooms 2 and 4

OPERATING ROOM 2	November 2011 P/m ³	November 2012 Ufc/m ³	March 2013 Ufc/m ³
	0.5 µm: 25586.7	0.5 µm: 637995.0	0.5 µm: 10893.6
	5 µm: 873.6	5 µm: 782.1	5 µm: 566.2

OPERATING ROOM 4	November 2011 Ufc/m ³	November 2012 Ufc/m ³	March 2013 Ufc/m ³
	0.5 µm: 103907.4	0.5 µm: 139485.3	0.5 µm: 6131.5
	5 µm: 1807.7	5 µm: 2613,4	5 µm: 652.5